

Received: 07/12/2018 Completed: 07/23/2018 Letter: C2 BG P.O.#: 4500027812 Test Report #: 3-27312-0-02

Client's Identification Item: 4013-05181. SPS-175. Date of Mfg.: 6/26/18. Product End Use: Upholstery.

Tested For: **Kristi Rygh** Key Test: NFPA 260 Cover Fabric (BLDG) 235
 Uniroyal Engineered Products, LLC
 501 South Water Street Tel: 1-(608)-873-6631 Ext:
 Stoughton, WI 53589 Fax: 1-()- -

Category: NFPA 260 Fabric LE 2013; V 04/18 PC: 4H NTR 4/16 dl/jd SM/mg
 NFPA 101 LE 2015; V 04/15
 IFC LE 2015; V 03/15

TEST PERFORMED: NFPA 260 Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture; Cover Fabric Test

Ignition Source: SRM 1196 Cigarette

SPECIMEN TEST COMPOSITE:

Candidate Cover Fabric: See "Client's Identification"
 Standard Filling Material: Non FR polyurethane foam, density 20 kg/m³ to 25 kg/m³

RESULTS:	TEST	RETEST (If Required)		
Specimen #	Ignition (yes/no/SE)	Char Length on Vertical Panel (mm)	Ignition (yes/no/SE)	Char Length on Vertical Panel (mm)
1	SE	0	SE	0
2	SE	0	SE	0
3	SE	0	SE	0

ABBREVIATION WHICH MAY BE USED:

SE = Indicates that the cigarette self extinguished prior to burning its entire length. When this occurs, a "retest" of that specimen is performed.

EC = Escalating combustion. Specimen extinguished by technician. No char length measurement taken.

CLASSIFICATION SYSTEM:

Class I - For each specimen: No obvious ignition; maximum char length 45 mm (1.75"). (Indicates propensity to resist cigarette ignition in conjunction with standard foam filling material.)

Class II - For any specimen: Obvious ignition; or char length exceeding 45 mm (1.75"). (Indicates inability to resist cigarette ignition in conjunction with standard foam filling material.)



GOVMARK

96-D Allen Boulevard
Farmingdale, New York 11735-5626 USA
Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956
e-mail: testing@govmark.com

Received:07/12/2018	Completed:07/23/2018	Letter: C2	BG	P.O.#: 4500027812	Test Report #:	3-27312-0-02
---------------------	----------------------	------------	----	-------------------	----------------	--------------

Client's Identification Item: 4013-05181. SPS-175. Date of Mfg.: 6/26/18. Product End Use: Upholstery.

Tested For: Kristi Rygh Uniroyal Engineered Products, LLC 501 South Water Street Stoughton, WI 53589	Key Test: NFPA 260 Cover Fabric (BLDG) 235 Tel: 1-(608)-873-6631 Fax: 1-()- -	Ext:
--	--	------

CONCLUSION: Based on the reported Results and cited Classification System, the item tested is assigned a:

Class I rating; Class II rating

REMARKS: None.

CODE INFORMATION:

- (1) The 2015 Edition of the NFPA Life Safety Code 101, paragraph 10.3.2.1(1); and
- (2) The 2015 Edition of the International Fire Code, paragraph 805.1.1.1, 805.2.1.1, 805.3.1.1, and 805.4.1.1

Upholstered furniture components shall be Class I when tested in accordance with NFPA 260 when specified by certain occupancies (provided that they are sprinklered throughout). The typical occupancies are:

- Healthcare
- Lodging & Rooming Houses
- Hotels
- Dormitories
- Residential Board & Care

NOTE: Non-sprinklered occupancies may require ASTM E1537.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified above.

Phyllis Pettit
AUG 02 2018

AUTHORIZED SIGNATURE

SGS GOVMARK

/ jab