



GOVMARK

96-D Allen Boulevard
Farmingdale, New York 11735-5626 USA
Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956
e-mail: testing@govmark.com

Page 1

Received: 07/12/2018 Completed: 07/23/2018 Letter: B2 BG P.O.#: 4500027812 Test Report #: 3-27311-0-02

Client's Identification

Item: 4030-05181. SPS-235/245. Date of Mfg.: 6/28/18. Product End Use: Upholstery.

Tested For: Kristi Rygh

Uniroyal Engineered Products, LLC
501 South Water Street
Stoughton, WI 53589

Key Test: NFPA 260 Cover Fabric (BLDG)

235

Tel: 1-(608)-873-6631

Ext:

Fax: 1-()- -

Category: NFPA 260 Fabric LE 2013; V 04/18 PC: 4H NTR 4/16 dl/jd SM/mg
NFPA 101 LE 2015; V 04/15
IFC LE 2015; V 03/15

TEST PERFORMED: NFPA 260 Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture; Cover Fabric Test

Ignition Source: SRM 1196 Cigarette

SPECIMEN TEST COMPOSITE:

Candidate Cover Fabric: See "Client's Identification"

Standard Filling Material: Non FR polyurethane foam, density 20 kg/m³ to 25 kg/m³

RESULTS:

TEST

RETEST (If Required)

| Specimen # | Ignition (yes/no/SE) | Char Length on Vertical Panel (mm) | Ignition (yes/no/SE) | Char Length on Vertical Panel (mm) |
|------------|-------------------------|--|-------------------------|--|
| 1 | SE | 0 | SE | 0 |
| 2 | SE | 0 | SE | 0 |
| 3 | SE | 0 | SE | 0 |

ABBREVIATION WHICH MAY BE USED:

SE = Indicates that the cigarette self extinguished prior to burning its entire length. When this occurs, a "retest" of that specimen is performed.

EC = Escalating combustion. Specimen extinguished by technician. No char length measurement taken.

CLASSIFICATION SYSTEM:

Class I - For each specimen: No obvious ignition; maximum char length 45 mm (1.75"). (Indicates propensity to resist cigarette ignition in conjunction with standard foam filling material.)

Class II - For any specimen: Obvious ignition; or char length exceeding 45 mm (1.75"). (Indicates inability to resist cigarette ignition in conjunction with standard foam filling material.)

-- See Page 2 for "Conclusion" --
(Page 1 of 2)



GOVMARK

96-D Allen Boulevard
Farmingdale, New York 11735-5626 USA
Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956
e-mail: testing@govmark.com

Page 2

| | | | | | |
|--|--|------------|---|-------------------|-----------------------------|
| Received: 07/12/2018 | Completed: 07/23/2018 | Letter: B2 | BG | P.O.#: 4500027812 | Test Report #: 3-27311-0-02 |
| Client's Identification | Item: 4030-05181. SPS-235/245. Date of Mfg.: 6/28/18. Product End Use: Upholstery. | | | | |
| Tested For: Kristi Rygh Uniroyal Engineered Products, LLC 501 South Water Street Stoughton, WI 53589 | | | Key Test: NFPA 260 Cover Fabric (BLDG) 235 Tel: 1-(608)-873-6631 Ext: Fax: 1-()- - | | |

CONCLUSION: Based on the reported Results and cited Classification System, the item tested is assigned a:

☒ Class I rating; ☐ Class II rating

REMARKS: None.

CODE INFORMATION:

- (1) The 2015 Edition of the NFPA Life Safety Code 101, paragraph 10.3.2.1(1); and
- (2) The 2015 Edition of the International Fire Code, paragraph 805.1.1.1, 805.2.1.1, 805.3.1.1, and 805.4.1.1

Upholstered furniture components shall be Class I when tested in accordance with NFPA 260 when specified by certain occupancies (provided that they are sprinklered throughout). The typical occupancies are:

Healthcare
Lodging & Rooming Houses
Hotels
Dormitories
Residential Board & Care

NOTE: Non-sprinklered occupancies may require ASTM E1537.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified above.

Phyllis Pettit

AUG 02 2018

AUTHORIZED SIGNATURE
SGS GOVMARK
/jab /gb

(Page 2 of 2)